



PARTS HISTORY LOG

Radiation Testing

PROGRAMME:- XMM

PART TYPE:- UC1856J

RADIATION REPORT:- RD 241

IGG TASK NUMBER:- 1500

SUMMARY OF TEST RESULTS

S/Nos 21 and 22 failed $I_{N-LATCH}$ after 15KRads(Si). However, S/No 22 subsequently passed this parameter at all the following test stages. In addition, S/No 21 failed I_{SOURCE} after 20KRads(Si). All samples failed a combination of V_{REF} , I_{SOURCE} or $I_{N-LATCH}$ after 30kRads(Si). Various other parameters also drifted significantly across the radiation test sequence. During post annealing electrical measurements S/No 26 failed catastrophically after being overstressed due to a test fixture anomaly.



Radiation Report Number:- RD 241

Project:- XMM

Part Type:- UC1856J

Date Code:- 9344A

Manufacturer:- Unitrode

IGG Task No:- 1500

Project Approval of Lot Traveller:-

Signed..... *M. Wankel* 

Date..... *11-09-97*

Position..... *PROJECT T.R.*

Serial Number Range:-

18 through 27 (not inclusive)

I certify that the subject component has been tested in accordance with the following radiation specifications:-

Test Method - ESA/SCC22900

ISSUE- 4 DATE- Jan '95

Irradiation Test Plan - HUY-IP-IGG-016

ISSUE- 1 DATE- Oct '96

Amendment to Plan - N50858

Closed/Approved NCR No:- N *N/A*

Approved Waiver No:- WAR *N/A*

Signed..... *P. H. Russell*

Date..... *11/9/97*

Upscreening Engineer

Signed... *[Signature]*

Date..... *11/9/97*

Upscreening Manager



Page 3 of 7

RADIATION REPORT NUMBER:- RD 241

DATE:- 9.9.97

PROJECT:- XMM

RIR IN:- 55163

PART NUMBER:- UC1856J

MANUFACTURER:- Unitrode







PROCUREMENT LEVEL:- HUYIG10501B

DATE CODE:- 9344A










TEST METHOD:- ESA/SCC22900 ISSUE- 4 DATE- Jan '95

TEST PLAN:- HUY-IP-IGG-016 ISSUE- 1 DATE- Oct '96












START QUANTITY:- 5

No.	Test (Sample Size)	HUY-IP-IG-016 Test Method and Conditions	Date in	Qty in	Date out	Qty out	SIGNED Op/QA
1	Serialisation and Selection of Control Sample (100%)	Control Sample= SN 18	4/8/97	5	4/8/97	4 + CONTROL SAMPLE	 IGG 16 CT
2	Initial Electrical Measurements (100% read and record)	Table A Testing at IGG	4/8/97	4	4/8/97	4	 IGG 16 CT
3	Initial Electrical Measurements (100% read and record)	Table A Testing at ERA	5/8/97	4	5/8/97	4	 IGG 16 CT
4	Set-up and apply Bias per Figure 1	Verify Bias Circuit and conditions (in-situ) for all 4 test samples	5/8/97	4	5/8/97	4	 IGG 16 CT
5	Irradiation 1 (4 samples)	Dose= 10kRAD(Si) Rate= 3RAD(Si) per second Time=3333secs	5/8/97	4	5/8/97	4	 IGG 16 CT
6	Interim 1 Electrical Measurements (100% read and record)	Table A. Bias to be maintained until testing is performed. Tdwel=10mins maximum	5/8/97	4	5/8/97	4	 IGG 16 CT



Report No: RD 241		Part Type: UC1856J			Date: 9.9.97		
No.	Test (Sample Size)	HUY-IP-IG-016 Test Method and Conditions	Date in	Qty in	Date out	Qty out	SIGNED Op/QA
7	Irradiation 2 (4 samples)	Dose= 5kRAD(Si) Rate= 3RAD(Si) per second Time=1667secs	5/8/97	4	5/8/97	4	 IGG 16 CT
8	Interim 2 Electrical Measurements (100% read and record)	As Test 6	5/8/97	4	5/8/97	2	 IGG 16 CT
9	Irradiation 3 (4 samples)	As Test 7	5/8/97	4	5/8/97	4	 IGG 16 CT
10	Interim 3 Electrical Measurements (100% read and record)	As Test 6	5/8/97	4	5/8/97	3	 IGG 16 CT
11	Irradiation 4 (4 samples)	As Test 5	5/8/97	4	5/8/97	4	 IGG 16 CT
12	Final Electrical Measurements (100% read and record)	As Test 6 At ERA	5/8/97	4	5/8/97	0	 IGG 16 CT
13	Annealing Test (4 samples)	Bias for 24hrs min at +25°C (record exact time)	5/8/97	4	6/8/97	4	 IGG 16 CT
14	Post Annealing Electrical Measurements (100% read and record)	Table A	7/8/97	4	7/8/97	0	 IGG 16 CT
15	Accelerated Aging under bias (4 samples)	168 hours bias at +100±5°C	7/8/97	3	14/8/97	3	 IGG 16 CT



Report No: RD 241		Part Type: UC1856J			Date: 9.9.97		
No.	Test (Sample Size)	HUY-IP-IG-016 Test Method and Conditions	Date in	Qty in	Date out	Qty out	SIGNED Op/QA
16	Post Aging Electrical Measurements (100% read and record)	Table A	15/8/97	3	15/8/97	0	 IGG 16 CT
17	Test Report Collation				11/9/97		 IGG 2 CT
18	Test Report Approval				11/9/97		 IGG 2 CT
19	NOTES:-						



FAILURE LIST AND APPLICABLE NCR

Test No.	Serial Number(s)	Failed Parameter and Failure Mode	Applicable NCR
8	21, 22	FAILED I-N-LATCH.	-
10	21	FAILED I-SOURCE.	-
12	21 22 26 27	FAILED VREF. FAILED I-SOURCE AND VREF. FAILED I-SOURCE. FAILED I-SOURCE AND I-N-LATCH.	-
14	26 27	FAILED SEVERAL PARAMETERS DUE TO TEST FIXTURE ANOMALY. FAILED VOL2 AND VOL3.	-
16	21, 22 27	FAILED VRLINE AND VOL2 FAILED CMRR, VREF, VRLINE, VOL2, VOL3.	-



RADIATION TEST SUMMARY

PART TYPE : UC1856J


DESCRIPTION : PWM CONTROLLER I.C.

REPORT NO. : RD241

PARAMETERS PLOTTED :

I-IB1
I-IO1
I-SOURCE
V-REF
I-IB2
I-IB3
I-N-LATCH
V-OL2
V-OL3


NOTE: The results for the remaining parameters showed no significant change and hence plots were not considered necessary.
S/No 26 has been excluded from the statistical analysis post anneal as it failed due to a test fixture anomaly (IGG fax no. D79453 refers).



Dose (kRad)	Control 18 (uA)	Mean (uA)	Max (uA)	Min (uA)	Lower Limit (uA)	Upper Limit (uA)	Std.Dev.
Initial	-0.13	-0.12	-0.11	-0.13	-1.0	1.0	0.01
0	-0.12	-0.13	-0.12	-0.13	-1.0	1.0	0.01
10	-0.11	-0.32	-0.31	-0.33	-1.0	1.0	0.01
15	-0.12	-0.43	-0.42	-0.44	-1.0	1.0	0.01
20	-0.13	-0.56	-0.53	-0.58	-1.0	1.0	0.02
30	-0.12	-0.85	-0.81	-0.88	-1.0	1.0	0.03
Anneal	-0.13	-0.84	-0.80	-0.88	-1.0	1.0	5.87
Final	-0.12	-0.50	-0.48	-0.52	-1.0	1.0	0.02

Lot size for statistics : 4 devices


RD 241 Date Code: 9344A



Dose (kRad)	Control 18 (uA)	Mean (uA)	Max (uA)	Min (uA)	Lower Limit (uA)	Upper Limit (uA)	Std.Dev.
Initial	-0.12	-0.12	-0.11	-0.12	-1.0	1.0	0.01
0	-0.12	-0.12	-0.11	-0.13	-1.0	1.0	0.01
10	-0.10	-0.30	-0.28	-0.31	-1.0	1.0	0.01
15	-0.11	-0.39	-0.39	-0.40	-1.0	1.0	0.00
20	-0.12	-0.51	-0.47	-0.53	-1.0	1.0	0.03
30	-0.12	-0.74	-0.68	-0.76	-1.0	1.0	0.04
Anneal	-0.12	-0.74	-0.68	-0.79	-1.0	1.0	5.93
Final	-0.11	-0.48	-0.47	-0.49	-1.0	1.0	0.01

Lot size for statistics : 4 devices

RD 241 Date Code: 9344A




Dose (kRad)	Control 18 (nA)	Mean (nA)	Max (nA)	Min (nA)	Upper Limit (nA)	Lower Limit (nA)	Std.Dev.
Initial	11.50	7.21	13.83	2.00	500	-	5.81
0	5.67	5.33	9.67	0.33	500	-	3.98
10	6.17	22.38	25.83	18.00	500	-	3.57
15	14.50	35.92	48.83	29.17	500	-	8.80
20	3.00	53.75	63.33	48.50	500	-	6.55
30	1.17	111.17	128.17	98.50	500	-	13.86
Anneal	5.50	105.00	126.33	89.17	500	-	53.43
Final	13.00	24.16	30.83	17.83	500	-	6.51

Lot size for statistics : 4 devices

RD 241 Date Code: 9344A




Radiation Results for I-SOURCE



Dose (kRad)	Control 18 (mA)	Mean (mA)	Max (mA)	Min (mA)	Upper Limit (mA)	Lower Limit (mA)	Std.Dev.
Initial	-0.49	-0.49	-0.48	-0.50	-0.4	-	0.01
0	-0.49	-0.49	-0.48	-0.50	-0.4	-	0.01
10	-0.48	-0.45	-0.44	-0.46	-0.4	-	0.01
15	-0.49	-0.43	-0.42	-0.43	-0.4	-	0.00
20	-0.48	-0.41	-0.39	-0.41	-0.4	-	0.01
30	-0.49	-0.37	-0.36	-0.38	-0.4	-	0.01
Anneal	-0.50	-0.39	-0.38	-0.40	-0.4	-	12.34
Final	-0.50	-0.45	-0.44	-0.46	-0.4	-	0.01

Lot size for statistics : 4 devices


RD 241 Date Code: 9344A



Dose (kRad)	Control 18 (V)	Mean (V)	Max (V)	Min (V)	Lower Limit (V)	Upper Limit (V)	Std.Dev.
Initial	5.09	5.11	5.13	5.09	5.05	5.15	0.02
0	5.09	5.11	5.11	5.09	5.05	5.15	0.01
10	5.09	5.10	5.11	5.08	5.05	5.15	0.01
15	5.10	5.09	5.10	5.07	5.05	5.15	0.02
20	5.09	5.08	5.09	5.05	5.05	5.15	0.02
30	5.09	5.06	5.10	5.01	5.05	5.15	0.04
Anneal	5.10	5.05	5.10	5.01	5.05	5.15	0.45
Final	5.10	5.00	5.01	4.98	5.05	5.15	0.02

Lot size for statistics : 4 devices


RD 241 Date Code: 9344A



Dose (kRad)	Control 18 (uA)	Mean (uA)	Max (uA)	Min (uA)	Lower Limit (uA)	Upper Limit (uA)	Std.Dev.
Initial	-0.43	-0.47	-0.44	-0.50	-3.00	-	0.03
0	-0.43	-0.47	-0.45	-0.50	-3.00	-	0.02
10	-0.44	-1.14	-1.13	-1.16	-3.00	-	0.01
15	-0.44	-1.53	-1.47	-1.57	-3.00	-	0.04
20	-0.43	-1.88	-1.73	-1.96	-3.00	-	0.10
30	-0.43	-2.58	-2.23	-2.73	-3.00	-	0.24
Anneal	-0.44	-2.52	-2.24	-2.68	-3.00	-	5.03
Final	-0.42	-1.58	-1.52	-1.70	-3.00	-	0.10

Lot size for statistics : 4 devices


RD 241 Date Code: 9344A



Dose (kRad)	Control 18 (uA)	Mean (uA)	Max (uA)	Min (uA)	Lower Limit (uA)	Upper Limit (uA)	Std.Dev.
Initial	-0.43	-0.41	-0.32	-0.48	-3.00	-	0.07
0	-0.42	-0.46	-0.43	-0.48	-3.00	-	0.02
10	-0.42	-1.12	-1.10	-1.15	-3.00	-	0.02
15	-0.42	-1.44	-1.26	-1.55	-3.00	-	0.13
20	-0.43	-1.86	-1.73	-1.94	-3.00	-	0.09
30	-0.43	-2.58	-2.30	-2.71	-3.00	-	0.19
Anneal	-0.42	-2.53	-2.34	-2.63	-3.00	-	5.03
Final	-0.60	-1.66	-1.49	-1.77	-3.00	-	0.15

Lot size for statistics : 4 devices


RD 241 Date Code: 9344A



Dose (kRad)	Control 18 (uA)	Mean (uA)	Max (uA)	Min (uA)	Lower Limit (uA)	Upper Limit (uA)	Std.Dev.
Initial	-7.02	-6.75	-6.56	-6.89	-30.0	-	0.14
0	-7.19	-6.76	-6.48	-6.97	-30.0	-	0.22
10	-7.04	-12.93	-12.43	-13.26	-30.0	-	0.36
15	-6.91	-15.32	-14.68	-15.93	-30.0	-	0.60
20	-6.98	-17.34	-17.10	-17.78	-30.0	-	0.30
30	-7.06	-22.61	-22.10	-22.94	-30.0	-	0.37
Anneal	-6.68	-23.45	-23.28	-23.56	-30.0	-	11.73
Final	-6.80	-19.67	-19.50	-19.85	-30.0	-	0.18

Lot size for statistics : 4 devices

RD 241 Date Code: 9344A




Dose (kRad)	Control 18 (mA)	Mean (mA)	Max (mA)	Min (mA)	Lower Limit (mA)	Upper Limit (mA)	Std.Dev.
Initial	2.56	2.53	2.59	2.51	0.8	3.0	0.04
0	2.52	2.53	2.55	2.51	0.8	3.0	0.02
10	2.52	2.61	2.70	2.51	0.8	3.0	0.08
15	2.51	2.87	3.11	2.58	0.8	3.0	0.28
20	2.52	2.77	3.11	2.59	0.8	3.0	0.24
30	2.51	2.92	3.11	2.71	0.8	3.0	0.21
Anneal	2.55	2.70	2.72	2.67	0.8	3.0	1.35
Final	2.52	1.71	2.61	0.00	0.8	3.0	1.48

Lot size for statistics : 4 devices

RD 241 Date Code: 9344A



Radiation Results For VOL2




Dose (kRad)	Control 18 (V)	Mean (V)	Max (V)	Min (V)	Upper Limit (V)	Lower Limit (V)	Std.Dev.
Initial	0.31	0.29	0.30	0.29	0.5	-	0.01
0	0.28	0.29	0.30	0.29	0.5	-	0.01
10	0.31	0.29	0.29	0.28	0.5	-	0.00
15	0.29	0.30	0.32	0.29	0.5	-	0.01
20	0.31	0.31	0.33	0.29	0.5	-	0.02
30	0.31	1.92	6.67	0.30	0.5	-	3.17
Anneal	0.32	2.41	6.56	0.29	0.5	-	3.15
Final	0.29	7.42	12.42	3.18	0.5	-	4.67

Lot size for statistics : 4 devices

RD 241 Date Code: 9344A



Radiation Results for VOL3



Dose (kRad)	Control 18	Mean	Max	Min	Upper Limit	Lower Limit	Std.Dev.
	(V)	(V)	(V)	(V)	(V)	(V)	
Initial	0.82	0.83	0.88	0.76	2.6	-	0.05
0	0.81	0.83	0.89	0.79	2.6	-	0.04
10	0.80	0.95	1.07	0.79	2.6	-	0.12
15	0.84	1.09	1.25	0.93	2.6	-	0.13
20	0.80	1.20	1.37	0.98	2.6	-	0.16
30	0.81	1.44	1.74	1.14	2.6	-	0.25
Anneal	0.98	1.38	1.68	1.07	2.6	-	5.85
Final	0.83	5.28	13.50	0.87	2.6	-	7.13

Lot size for statistics : 4 devices

RD 241 Date Code: 9344A

**IRRADIATION TEST PLAN NO.**

HUY-IP-IG-016

Issue No: 1
Date: October 1996
Page: 1/6

Rev.

HUYGENS RD241

1

2

Component No.

HUYIG10501B

3

Component Designation:-

Integrated Circuit, PWM Controller,
Type UC1856J

4

Irradiation Spec No. N/A

Iss. Rev.

5

Specifications

Detail HUY-SP-IG-105 Issue 2

6

Acceptance

Evaluation _____
Element _____
Diffusion _____
Lot X

7

Electrical Meas

In-situ _____
Remote X

8

Project/Programme

HUYGENS

9

Manufacturer: Name: Unitrode/USA
Address: 7 Continental Boulevard
Merrimack
NH 03054-0399

Tel: 603 429 8610

10

Test Facility: Name: ERA
Address: Leatherhead
Surrey
England

11

Originator: IGG CT
Name: S Thacker

Telephone: (01329) 829311

12

Radiation Source

COBALT 60

13

Sample Size: 4

Control Devices: 1

14

Exposure

Single _____
Multiple X

15

Annealing Test

YES X NO _____

16

Radiation Level:

10KRad(Si) 20KRad(Si)
15KRad(Si) 30KRad(Si)

17

Single Exposure
Dose [KRad(Si)]
Dose Rate [Rad(Si)/s]
Exposure Time

18

Multiple Exposure +
Irradiation Steps

1

2

3

4

Dose [Krad(Si)]

10

5

5

10

Dose Rate [Rad(Si)/sec]

3

3

3

3

Exposure Time(s)

3333

1667

1667

3333

19

Bias Requirements: During and after Exposure (for remote Electrical Measurements): YES**Bias Conditions:**

Test Circuits: The Electrical Bias circuit is given in Figure 1

Shielding:

Shielding is required to minimise dose enhancement effects caused by low energy, scattered radiation. The test specimens shall be enclosed in a Pb/Al container of Pb 1.5mm minimum, surrounding an inner shield of 0.7 to 1.0mm Al.

20

Irradiation Test Sequence

21

TEST STEP	DESCRIPTION	REQUIREMENTS
1	Irradiation Test Samples Selection	Quantity 5 devices shall be selected from the lot delivered to IGG.
2	Serialisation	Serialisation - (if the devices are not already serialised). Test units shall be serialised 1 to 4 and the control unit shall be 5.
3	Initial Electrical Measurements (at IGG)	Per Table A herein - (Read & Record) - on all 5 parts at IGG. (See Remarks 1 and 2).



HUYGENS

IRRADIATION TEST PLAN NO.

HUY-IP-IG-016

Issue No. 1

Date: October 1996

Page: 2/6

Rev.

1

2

TEST STEP	DESCRIPTION	REQUIREMENTS
4	Initial Electrical Measurements	Per Table A herein - (Read & Record) - on all 5 parts at ERA. (See Remarks 1 and 2).
5	Set-Up of Test	Verify bias circuit and voltages (in-situ) for 4 test units.
6	Irradiation Exposure	Verify dose rate and position in the chamber to achieve required dose. Verify and witness duration of exposure to achieve required dose. (See Remark 3).
7	Intermediate Electrical Measurement (at ERA)	Bias to be maintained until test is performed. Test per Table A herein - (Read & Record) - on all 5 parts. Test to be performed immediately upon removal from chamber (less than 10 mins interval). Upon completion of test 4 test units shall be replaced in bias circuit and returned to chamber. Maximum interval between 2 consecutive exposures to be 30 mins. (See Remark 2).
8 to 16	Repeat Set-up/Exposure/Test sequence upto a Final Total Dose of 30KRad(Si)	Repeat steps 5, 6,7 for a total of 4 cycles as per multiple exposure in Box No: 19. (See Remark 4)
17	Annealing	Bias shall be maintained during Annealing for 4 test units. Annealing shall be at room temperature for 24 hours.
18	Post-Annealing Electrical Measurements (at IGG)	Per Table A herein - Read & Record - on all 5 parts at IGG. (See Remark 2).
19	Accelerated Aging Under Bias	Bias shall be maintained during Aging for 5 test units. Aging shall be at $T_{amb} = +100 \pm 5^{\circ}C$ for 168 hours.
20	Final Electrical Measurements (at IGG)	Per Table A herein - (Read & Record) - on all 5 parts at IGG. (See Remark 2).
21	Total Dose Irradiation Test Report	ESA/SCC No: 22900.

REMARKS:-

22

1. The initial electrical measurements performed at IGG (Test Step 3) shall be performed within 24 hours of the initial electrical measurements at ERA (Test Step 4).
2. All electrical testing shall be performed on the same set of equipment in order to achieve correlation of results both at IGG and ERA. All results plus details of any failures shall be advised to Project.
3. The dose rates and exposure times given above may be adjusted during irradiation testing to achieve convenient test points, but shall not exceed the limits specified in Box No: 19. The dose rates and exposure times used during the testing shall be recorded for each test step.
4. The set-up/exposure/test sequence shall be stopped for any device that exhibits repeated functional failure.



**TABLE A - ELECTRICAL MEASUREMENTS AT ROOM TEMPERATURE - TAMB = +25 ± 5°C
BEFORE, AT INTERMEDIATE POINTS AND ON COMPLETION OF IRRADIATION TESTING**

NO		CHARACTERISTICS	SYMBOL	TEST METHOD MIL-STD-883	TEST CONDITIONS	LIMITS		UNIT
						MIN	MAX	
1	REFERENCE SECTION	Output Voltage	V_{REF}	-	$T_j = 25^\circ C$ $I_o = 1mA$	5.05	5.15	V
2		Line Regulation	V_{RLINE}	-	$V_{IN} = 8V$ to 40V	-	20	mV
3		Load Regulation	V_{RLOAD}	-	$I_L = 1mA$ to 10mA	-	15	mV
6	OSCILLATOR SECTION	Sync Output Voltage High Level	V_{SOH}	-	$I_o = -1mA$	2.4	-	V
7		Sync Output Voltage Low Level	V_{SOL}	-	$I_o = +1mA$	-	0.4	V
12	ERROR AMPLIFIER SECTION	Input Bias Current 1	I_{IB1}	4001		-1	1	μA
13		Input Offset Current 1	I_{IO1}	4001		-	500	nA
14		Open Loop Voltage Gain	A_{VS}	4004	$\Delta V_o = 1.2V$ to 3V $V_{CM} = 2V$ (See Note 3)	80	-	dB
15		Common Mode Rejection Ratio 1	$CMRR_1$	4003	$V_{CM} = 0V$ to 38V $V_{IN} = 40V$ (See Note 4)	75	-	dB
18		Output Source Current (Pin 7)	I_{SOURCE}	-	$V_{ID} = 15mV$ COMPENSATION (Pin 7) = 2.5V	-	-0.4	mA
19		High Level Output Voltage 1	V_{OH1}	-	R_L (Pin 7) = 15K Ω $V_{ID} = 50mV$	4.3	4.9	V
20		Low Level Output Voltage 1	V_{OL1}	-	R_L (Pin 7) = 15K Ω $V_{ID} = 50mV$	-	1.0	V
21	CURRENT SENSE AMPLIFIER SECTION	Amplifier Gain	A_v	-	Pin 3 = 0V Pin 1 = OPEN (See Notes 6 & 7)	2.5	3.0	V/V
26		Input Bias Current 2	I_{IB2}	4001	Pin 1 = 0.5V Pin 7 = OPEN (See Note 6)	-	3	μA
27		Input Offset Current 2	I_{IO2}	4001	Pin 1 = 0.5V Pin 7 = OPEN (See Note 6)	-	1	μA

NOTES:- See Page 5.




**TABLE A - ELECTRICAL MEASUREMENTS AT ROOM TEMPERATURE - TAMB = +25 ± 5°C
 BEFORE, AT INTERMEDIATE POINTS AND ON COMPLETION OF IRRADIATION TESTING - (CONTINUED...)**

NO		CHARACTERISTICS	SYMBOL	TEST METHOD MIL-STD-883	TEST CONDITIONS (SEE NOTE 1)	LIMITS		UNIT	
						MIN	MAX		
29	CURRENT LIMIT ADJUST SECTION	Input Bias Current 3	I_{IB3}	4001	Pin 5 = V_{REF} Pin 6 = 0V	-	30	μA	32
31	SHUTDOWN TERMINAL SECTION	Minimum Latching Current (Pin 1)	I_{LATCH}	-	See Note 8	3.0	-	mA	34
32		Maximum Non-Latching Current (Pin 1)	$I_{N-LATCH}$	-	See Note 9	-	0.8	mA	34
34	OUTPUT SECTION	Collector Leakage Current	I_C	-	$V_C = 40V$	-	200	μA	37
35		Low Level Output Voltage 2	V_{OL2}	-	$I_{SINK} = 20mA$	-	0.5	V	38
36		Low Level Output Voltage 3	V_{OL3}	-	$I_{SINK} = 200mA$	-	2.6	V	39
41	TOTAL STANDBY	Supply Current	I_{IN}	-	-	-	23	mA	41

NOTES:- See Page 5.



FIGURE 5(b) - ELECTRICAL CIRCUIT FOR IRRADIATION TESTING



NOTES:-

1. All resistors are $\pm 5\%$ $\frac{1}{8}W$.
2. All Capacitors are $\pm 10\%$ 50V
3. $V_{cc} = 35V$, $I_{cc} = 14mA$.

Results file : RD241 UC1856J INIT EMS @ IGG from: 04.08.97 / 09:27:45
 Operator : PAUL RUSSELL
 Part number : UC1856J
 Lot number : RD241
 Order number : D/C 9344A
 Vendor : UNITRODE
 : CONTROL 18 ; RAD 21,22,26,27
 : INITIAL EMS @ IGG
 : UC1856 HUY-SP-IG-105 ISSUE 2 RM / V1.0 IR 04/09/96 ROOMTEMP

Test steps

1. Supply Current	0.00	...	23.00	mA
2. Vos Error Amplifier	not active			
3. +I.Bias - Error Amp.	-1.00	...	0.00	uA
4. -I.Bias - Error Amp.	-1.00	...	0.00	uA
5. Ios - Error Amp.	0.00	...	500.00	nA
6. Avs Error Amplifier	80.000	...	120.000	dB
7. PSRR Error Amplifier	not active			
8. CMRR Error Amplifier	75.0	...	140.0	dB
9. I-Sink Error Amp.	not active			
10. I-Source Error Amp.	-10.00	...	-0.40	mA
11. V-oh Error Amplifier	4.30	...	4.90	V
12. V-ol Error Amplifier	0.00	...	1.00	V
13. V-ref Output Voltage	5.05	...	5.15	V
14. Line Regulation	0.0	...	20.0	mV
15. Load Regulation	0.0	...	15.0	mV
16. Isc - Voltage Ref.	not active			
17. Current Sense Gain	2.50	...	3.00	V/V
18. Current Sense V-Diff	not active			
19. Vos Current Sense	not active			
20. CMRR Current Sense	not active			
21. PSRR Current Sense	not active			
22. Current Sense +IBias	-3.00	...	0.00	uA
23. Current Sense -IBias	-3.00	...	0.00	uA
24. Current Sense Ios	0.00	...	1.00	uA
25. V-oh Sync Output	2.40	...	5.00	V
26. V-ol Sync Output	0.00	...	0.40	V
27. V-ih/V-il Sync Input	not active			
28. I-in Sync Input	not active			
29. Initial Accuracy	not active			
30. Voltage Stability	not active			
31. Vos Current Limit	not active			
32. Current Limit I-Bias	-30.00	...	0.00	uA
33. Shutdown V-th	not active			
34. Shutdown I-N-Latch	0.80	...	3.00	mA
35. UVLO Shutdown V-th	not active			
36. UVLO Start-Up V-th	not active			
37. Vc Leakage Current	0.00	...	200.00	uA
38. VOL @ 20mA	0.00	...	0.50	V
39. VOL @ 200mA	0.00	...	2.60	V
40. VOH @ 20mA	not active			
41. VOH @ 200mA	not active			

	18	21	22	26	27
1.1 [mA]	17.50	17.34	18.02	17.62	17.59
3.1 [uA]	-0.13	-0.13	-0.11	-0.12	-0.12
4.1 [uA]	-0.12	-0.12	-0.11	-0.11	-0.12
5.1 [nA]	11.50	10.33	2.00	13.83	2.67
6.1 [dB]	87.642	87.639	87.687	90.123	87.639
8.1 [dB]	93.4	93.4	93.4	93.4	93.4
10.1 [mA]	-0.49	-0.48	-0.50	-0.48	-0.49
11.1 [V]	4.63	4.64	4.66	4.66	4.68
12.1 [V]	0.72	0.73	0.73	0.73	0.75
13.1 [V]	5.09	5.09	5.12	5.11	5.13
14.1 [mV]	3.1	2.6	3.1	3.3	3.3
15.1 [mV]	0.9	0.5	2.1	1.0	9.1
17.1 [V/V]	2.60	2.60	2.60	2.60	2.60
22.1 [uA]	-0.43	-0.47	-0.44	-0.45	-0.50
23.1 [uA]	-0.43	-0.44	-0.32	-0.41	-0.48
24.1 [uA]	0.01	0.03	0.12	0.04	0.01
25.1 [V]	3.91	3.90	3.93	3.93	3.94
26.1 [V]	0.33	0.33	0.33	0.34	0.35
32.1 [uA]	-7.02	-6.89	-6.56	-6.78	-6.78
34.1 [mA]	2.56	2.59	2.51	2.51	2.51
37.1 [uA]	0.07	0.06	0.07	0.12	0.07
38.1 [V]	0.31	0.30	0.29	0.29	0.29
38.2 [V]	0.28	0.28	0.30	0.28	0.30
39.1 [V]	0.82	0.86	0.76	0.81	0.88
39.2 [V]	0.78	0.83	0.77	0.75	0.85

SZ-TESTSYSTEME Statistics 03 Vers. 2.15 for UT63
RD241_UC1856J_INIT_EMS@_ERA / V 1.0 IR 04/09/96 ROOM TEMP

Results file : RD241_UC1856J_INIT_EMS@_ERA from: 05.08.97 / 10:47:28
Operator : PAUL RUSSELL
Part number : UC1856J
Lot number : RD241
Order number : D/C 9344A
Vendor : UNITRODE
: CONTROL 18 ; RAD 21,22,26,27
: INITIAL EMS @ ERA
: UC1856 HUY-SP-IG-105 ISSUE 2 RM / V1.0 IR 04/09/96 ROOMTEMP

Test steps

1. Supply Current	0.00	...	23.00	mA
2. Vos Error Amplifier	not active			
3. +I.Bias - Error Amp.	-1.00	...	0.00	uA
4. -I.Bias - Error Amp.	-1.00	...	0.00	uA
5. Ios - Error Amp.	0.00	...	500.00	nA
6. Avs Error Amplifier	80.000	...	120.000	dB
7. PSRR Error Amplifier	not active			
8. CMRR Error Amplifier	75.0	...	140.0	dB
9. I-Sink Error Amp.	not active			
10. I-Source Error Amp.	-10.00	...	-0.40	mA
11. V-oh Error Amplifier	4.30	...	4.90	V
12. V-ol Error Amplifier	0.00	...	1.00	V
13. V-ref Output Voltage	5.05	...	5.15	V
14. Line Regulation	0.0	...	20.0	mV
15. Load Regulation	0.0	...	15.0	mV
16. Isc - Voltage Ref.	not active			
17. Current Sense Gain	2.50	...	3.00	V/V
18. Current Sense V-Diff	not active			
19. Vos Current Sense	not active			
20. CMRR Current Sense	not active			
21. PSRR Current Sense	not active			
22. Current Sense +IBias	-3.00	...	0.00	uA
23. Current Sense -IBias	-3.00	...	0.00	uA
24. Current Sense Ios	0.00	...	1.00	uA
25. V-oh Sync Output	2.40	...	5.00	V
26. V-ol Sync Output	0.00	...	0.40	V
27. V-ih/V-il Sync Input	not active			
28. I-in Sync Input	not active			
29. Initial Accuracy	not active			
30. Voltage Stability	not active			
31. Vos Current Limit	not active			
32. Current Limit I-Bias	-30.00	...	0.00	uA
33. Shutdown V-th	not active			
34. Shutdown I-N-Latch	0.80	...	3.00	mA
35. UVLO Shutdown V-th	not active			
36. UVLO Start-Up V-th	not active			
37. Vc Leakage Current	0.00	...	200.00	uA
38. VOL @ 20mA	0.00	...	0.50	V
39. VOL @ 200mA	0.00	...	2.60	V
40. VOH @ 20mA	not active			
41. VOH @ 200mA	not active			

		18	21	22	26	27
1.1	[mA	17.72	17.38	18.08	17.65	17.57
3.1	[uA	-0.12	-0.12	-0.12	-0.13	-0.13
4.1	[uA	-0.12	-0.11	-0.12	-0.12	-0.13
5.1	[nA	5.67	4.33	7.00	9.67	0.33
6.1	[dB	87.684	87.806	87.775	89.846	87.799
8.1	[dB	93.4	93.4	93.4	93.4	93.4
10.1	[mA	-0.49	-0.48	-0.50	-0.49	-0.49
11.1	[V	4.65	4.64	4.66	4.66	4.66
12.1	[V	0.74	0.73	0.73	0.73	0.73
13.1	[V	5.09	5.09	5.11	5.11	5.11
14.1	[mV	3.4	2.7	3.9	3.4	3.4
15.1	[mV	0.6	1.2	0.9	0.7	0.9
17.1	[V/V	2.60	2.60	2.60	2.60	2.60
22.1	[uA	-0.43	-0.46	-0.45	-0.47	-0.50
23.1	[uA	-0.42	-0.46	-0.43	-0.45	-0.48
24.1	[uA	0.01	0.01	0.03	0.02	0.02
25.1	[V	3.89	3.89	3.92	3.92	3.92
26.1	[V	0.33	0.33	0.33	0.34	0.34
32.1	[uA	-7.19	-6.89	-6.48	-6.71	-6.97
34.1	[mA	2.52	2.51	2.52	2.52	2.55
37.1	[uA	0.06	0.06	0.06	0.11	0.07
38.1	[V	0.28	0.30	0.29	0.29	0.29
38.2	[V	0.29	0.28	0.29	0.28	0.30
39.1	[V	0.81	0.89	0.79	0.80	0.83
39.2	[V	0.79	0.85	0.71	0.74	0.80

SZ-TESTSYSTEME Statistics 03 Vers. 2.15 for UTS3
 RD241_UC1856J_EMS_@_10_KRAD / V 1.0 IR 04/09/96 ROOM TEMP

 Results file : RD241_UC1856J_EMS_@_10_KRAD from: 05.08.97 / 11:01:33
 Operator : PAUL RUSSELL
 Part number : UC1856J
 Lot number : RD241
 Order number : D/C 9344A
 Vendor : UNITRODE
 : CONTROL 18 ; RAD 21,22,26,27
 : EMS @ 10 KRAD
 : UC1856 HUY-SP-IG-105 ISSUE 2 RM / V1.0 IR 04/09/96 ROOMTEMP

Test steps

1. Supply Current	0.00	...	23.00	mA
2. Vos Error Amplifier	not active			
3. +I.Bias - Error Amp.	-1.00	...	0.00	uA
4. -I.Bias - Error Amp.	-1.00	...	0.00	uA
5. Ios - Error Amp.	0.00	...	500.00	nA
6. Avs Error Amplifier	80.000	...	120.000	dB
7. PSRR Error Amplifier	not active			
8. CMRR Error Amplifier	75.0	...	140.0	dB
9. I-Sink Error Amp.	not active			
10. I-Source Error Amp.	-10.00	...	-0.40	mA
11. V-oh Error Amplifier	4.30	...	4.90	V
12. V-ol Error Amplifier	0.00	...	1.00	V
13. V-ref Output Voltage	5.05	...	5.15	V
14. Line Regulation	0.0	...	20.0	mV
15. Load Regulation	0.0	...	15.0	mV
16. Isc - Voltage Ref.	not active			
17. Current Sense Gain	2.50	...	3.00	V/V
18. Current Sense V-Diff	not active			
19. Vos Current Sense	not active			
20. CMRR Current Sense	not active			
21. PSRR Current Sense	not active			
22. Current Sense +IBias	-3.00	...	0.00	uA
23. Current Sense -IBias	-3.00	...	0.00	uA
24. Current Sense Ios	0.00	...	1.00	uA
25. V-oh Sync Output	2.40	...	5.00	V
26. V-ol Sync Output	0.00	...	0.40	V
27. V-ih/V-il Sync Input	not active			
28. I-in Sync Input	not active			
29. Initial Accuracy	not active			
30. Voltage Stability	not active			
31. Vos Current Limit	not active			
32. Current Limit I-Bias	-30.00	...	0.00	uA
33. Shutdown V-th	not active			
34. Shutdown I-N-Latch	0.80	...	3.00	mA
35. UVLO Shutdown V-th	not active			
36. UVLO Start-Up V-th	not active			
37. Vc Leakage Current	0.00	...	200.00	uA
38. VOL @ 20mA	0.00	...	0.50	V
39. VOL @ 200mA	0.00	...	2.60	V
40. VOH @ 20mA	not active			
41. VOH @ 200mA	not active			

	18	21	22	26	27
1.1 [mA]	17.70	17.00	17.72	17.38	17.32
3.1 [uA]	-0.11	-0.33	-0.31	-0.31	-0.32
4.1 [uA]	-0.10	-0.31	-0.28	-0.29	-0.30
5.1 [nA]	6.17	21.00	25.83	24.67	18.00
6.1 [dB]	87.733	87.680	87.740	87.831	87.691
8.1 [dB]	93.4	93.4	93.4	93.4	93.4
10.1 [mA]	-0.48	-0.44	-0.46	-0.45	-0.45
11.1 [V]	4.65	4.62	4.65	4.65	4.66
12.1 [V]	0.74	0.73	0.73	0.73	0.73
13.1 [V]	5.09	5.08	5.11	5.11	5.10
14.1 [mV]	3.0	4.0	3.8	4.8	6.6
15.1 [mV]	0.7	0.4	0.9	0.8	0.1
17.1 [V/V]	2.60	2.60	2.60	2.60	2.60
22.1 [uA]	-0.44	-1.14	-1.13	-1.16	-1.14
23.1 [uA]	-0.42	-1.12	-1.10	-1.15	-1.10
24.1 [uA]	0.03	0.02	0.03	0.01	0.03
25.1 [V]	3.90	3.88	3.91	3.90	3.90
26.1 [V]	0.33	0.33	0.33	0.34	0.34
32.1 [uA]	-7.04	-13.09	-12.43	-12.95	-13.26
34.1 [mA]	2.52	2.70	2.59	2.51	2.64
37.1 [uA]	0.06	0.06	0.06	0.12	0.07
38.1 [V]	0.31	0.29	0.28	0.29	0.29
38.2 [V]	0.28	0.28	0.28	0.30	0.30
39.1 [V]	0.80	1.07	0.79	0.97	0.96
39.2 [V]	0.79	1.02	0.78	0.90	0.98

SZ-TESTSYSTEME Statistics 03 VerS. 2.15 for UTS3
RD241_UC1856J_EMS_@_15_KRAD / V 1.0 IR 04/09/96 ROOM TEMP

Results file : RD241_UC1856J_EMS_@_15_KRAD from: 05.08.97 / 12:18:23
Operator : PAUL RUSSELL
Part number : UC1856J
Lot number : RD241
Order number : D/C 9344A
Vendor : UNITRODE
: CONTROL 18 ; RAD 21,22,26,27
: EMS @ 15 KRAD
: UC1856 HUY-SP-IG-105 ISSUE 2 RM / V1.0 IR 04/09/96 ROOMTEMP

Test steps

1. Supply Current	0.00	...	23.00	mA
2. Vos Error Amplifier	not active			
3. +I.Bias - Error Amp.	-1.00	...	0.00	uA
4. -I.Bias - Error Amp.	-1.00	...	0.00	uA
5. Ios - Error Amp.	0.00	...	500.00	nA
6. Avs Error Amplifier	80.000	...	120.000	dB
7. PSRR Error Amplifier	not active			
8. CMRR Error Amplifier	75.0	...	140.0	dB
9. I-Sink Error Amp.	not active			
10. I-Source Error Amp.	-10.00	...	-0.40	mA
11. V-oh Error Amplifier	4.30	...	4.90	V
12. V-ol Error Amplifier	0.00	...	1.00	V
13. V-ref Output Voltage	5.05	...	5.15	V
14. Line Regulation	0.0	...	20.0	mV
15. Load Regulation	0.0	...	15.0	mV
16. Isc - Voltage Ref.	not active			
17. Current Sense Gain	2.50	...	3.00	V/V
18. Current Sense V-Diff	not active			
19. Vos Current Sense	not active			
20. CMRR Current Sense	not active			
21. PSRR Current Sense	not active			
22. Current Sense +IBias	-3.00	...	0.00	uA
23. Current Sense -IBias	-3.00	...	0.00	uA
24. Current Sense Ios	0.00	...	1.00	uA
25. V-oh Sync Output	2.40	...	5.00	V
26. V-ol Sync Output	0.00	...	0.40	V
27. V-ih/V-il Sync Input	not active			
28. I-in Sync Input	not active			
29. Initial Accuracy	not active			
30. Voltage Stability	not active			
31. Vos Current Limit	not active			
32. Current Limit I-Bias	-30.00	...	0.00	uA
33. Shutdown V-th	not active			
34. Shutdown I-N-Latch	0.80	...	3.00	mA
35. UVLO Shutdown V-th	not active			
36. UVLO Start-Up V-th	not active			
37. Vc Leakage Current	0.00	...	200.00	uA
38. VOL @ 20mA	0.00	...	0.50	V
39. VOL @ 200mA	0.00	...	2.60	V
40. VOH @ 20mA	not active			
41. VOH @ 200mA	not active			

		18	21	22	26	27
1.1	[mA]	17.69	16.83	17.64	17.27	17.18
3.1	[uA]	-0.12	-0.43	-0.42	-0.44	-0.43
4.1	[uA]	-0.11	-0.40	-0.39	-0.39	-0.39
5.1	[nA]	14.50	32.17	29.17	48.83	33.50
6.1	[dB]	87.659	87.680	87.694	87.687	87.712
8.1	[dB]	93.4	93.4	93.4	93.4	93.4
10.1	[mA]	-0.49	-0.42	-0.43	-0.43	-0.43
11.1	[V]	4.65	4.62	4.65	4.65	4.65
12.1	[V]	0.74	0.73	0.74	0.74	0.73
13.1	[V]	5.10	5.07	5.10	5.10	5.10
14.1	[mV]	3.1	3.9	5.4	7.1	7.6
15.1	[mV]	2.5	1.6	1.9	0.7	0.0
17.1	[V/V]	2.60	2.60	2.60	2.60	2.60
22.1	[uA]	-0.44	-1.53	-1.54	-1.57	-1.47
23.1	[uA]	-0.42	-1.26	-1.50	-1.55	-1.45
24.1	[uA]	0.03	0.27	0.03	0.01	0.02
25.1	[V]	3.90	3.86	3.90	3.88	3.88
26.1	[V]	0.33	0.33	0.33	0.34	0.34
32.1	[uA]	-6.91	-15.72	-14.96	-14.68	-15.93
34.1	[mA]	2.51	3.11 F	3.11 F	2.58	2.67
37.1	[uA]	0.07	0.06	0.06	0.12	0.07
38.1	[V]	0.29	0.30	0.32	0.29	0.29
38.2	[V]	0.29	0.29	0.30	0.30	0.30
39.1	[V]	0.84	1.25	0.93	1.07	1.10
39.2	[V]	0.80	1.18	0.86	1.00	1.09

Results file : RD241_UC1856J_EMS_@_20_KRAD from: 05.08.97 / 12:51:28
Operator : PAUL RUSSELL
Part number : UC1856J
Lot number : RD241
Order number : D/C 9344A
Vendor : UNITRODE
: CONTROL 18 ; RAD 21,22,26,27
: EMS @ 20 KRAD
: UC1856 HUY-SP-I6-105 ISSUE 2 RM / V1.0 IR 04/09/96 ROOMTEMP

Test steps

1. Supply Current	0.00	...	23.00	mA
2. Vos Error Amplifier	not active			
3. +I.Bias - Error Amp.	-1.00	...	0.00	uA
4. -I.Bias - Error Amp.	-1.00	...	0.00	uA
5. Ios - Error Amp.	0.00	...	500.00	nA
6. Avs Error Amplifier	80:000	...	120.000	dB
7. PSRR Error Amplifier	not active			
8. CMRR Error Amplifier	75.0	...	140.0	dB
9. I-Sink Error Amp.	not active			
10. I-Source Error Amp.	-10.00	...	-0.40	mA
11. V-oh Error Amplifier	4.30	...	4.90	V
12. V-ol Error Amplifier	0.00	...	1.00	V
13. V-ref Output Voltage	5.05	...	5.15	V
14. Line Regulation	0.0	...	20.0	mV
15. Load Regulation	0.0	...	15.0	mV
16. Isc - Voltage Ref.	not active			
17. Current Sense Gain	2.50	...	3.00	V/V
18. Current Sense V-Diff	not active			
19. Vos Current Sense	not active			
20. CMRR Current Sense	not active			
21. PSRR Current Sense	not active			
22. Current Sense +IBias	-3.00	...	0.00	uA
23. Current Sense -IBias	-3.00	...	0.00	uA
24. Current Sense Ios	0.00	...	1.00	uA
25. V-oh Sync Output	2.40	...	5.00	V
26. V-ol Sync Output	0.00	...	0.40	V
27. V-ih/V-il Sync Input	not active			
28. I-in Sync Input	not active			
29. Initial Accuracy	not active			
30. Voltage Stability	not active			
31. Vos Current Limit	not active			
32. Current Limit I-Bias	-30.00	...	0.00	uA
33. Shutdown V-th	not active			
34. Shutdown I-N-Latch	0.80	...	3.00	mA
35. UVLO Shutdown V-th	not active			
36. UVLO Start-Up V-th	not active			
37. Vc Leakage Current	0.00	...	200.00	uA
38. VOL @ 20mA	0.00	...	0.50	V
39. VOL @ 200mA	0.00	...	2.50	V
40. VOH @ 20mA	not active			
41. VOH @ 200mA	not active			

	18	21	22	26	27
1.1 [mA]	17.68	16.44	17.40	17.05	17.01
3.1 [uA]	-0.13	-0.58	-0.56	-0.57	-0.53
4.1 [uA]	-0.12	-0.53	-0.51	-0.51	-0.47
5.1 [nA]	3.00	48.50	51.50	63.33	51.67
6.1 [dB]	87.733	87.701	87.806	87.708	87.771
8.1 [dB]	93.4	93.4	93.4	93.4	93.4
10.1 [mA]	-0.48	-0.39 F	-0.41	-0.41	-0.41
11.1 [V]	4.65	4.58	4.63	4.63	4.64
12.1 [V]	0.73	0.72	0.73	0.73	0.73
13.1 [V]	5.09	5.05	5.08	5.09	5.08
14.1 [mV]	3.0	5.9	7.4	7.1	9.1
15.1 [mV]	1.0	1.7	0.7	1.1	0.1
17.1 [V/V]	2.60	2.60	2.60	2.60	2.60
22.1 [uA]	-0.43	-1.90	-1.94	-1.96	-1.73
23.1 [uA]	-0.43	-1.88	-1.90	-1.94	-1.73
24.1 [uA]	0.00	0.02	0.04	0.03	0.00
25.1 [V]	3.90	3.86	3.88	3.86	3.86
26.1 [V]	0.33	0.33	0.33	0.34	0.34
32.1 [uA]	-6.98	-17.10	-17.78	-17.20	-17.29
34.1 [mA]	2.52	3.11 F	2.61	2.59	2.75
37.1 [uA]	0.07	0.06	0.06	0.12	0.07
38.1 [V]	0.31	0.30	0.29	0.30	0.33
38.2 [V]	0.29	0.29	0.29	0.30	0.30
39.1 [V]	0.80	1.37	0.98	1.21	1.22
39.2 [V]	0.81	1.30	0.93	1.08	1.17

SZ-TESTSYSTEME Statistics 03 VerS. 2.15 for UTS3
 RD241_UC1856J_EMS_@_30_KRAD / V 1.0 IR 04/09/96 ROOM TEMP

```

=====
Results file   : RD241_UC1856J_EMS_@_30_KRAD   from: 05.08.97 / 13:30:11
Operator      : PAUL RUSSELL
Part number   : UC1856J
Lot number    : RD241
Order number  : D/C 9344A
Vendor        : UNITRODE
               : CONTROL 18 ; RAD 21,22,26,27
               : EMS @ 30 KRAD
               : UC1856 HUY-SP-IG-105 ISSUE 2 RM / V1.0 IR 04/09/96 ROOMTEMP
=====

```

Test steps

```

1. Supply Current           0.00   ...   23.00   mA
2. Vos Error Amplifier     not active
3. +I.Bias - Error Amp.    -1.00   ...   0.00   uA
4. -I.Bias - Error Amp.    -1.00   ...   0.00   uA
5. Ios - Error Amp.        0.00   ...   500.00  nA
6. Avs Error Amplifier     80.000  ...   120.000 dB
7. PSRR Error Amplifier    not active
8. CMRR Error Amplifier    75.0    ...   140.0   dB
9. I-Sink Error Amp.       not active
10. I-Source Error Amp.    -10.00  ...   -0.40  mA
11. V-oh Error Amplifier   4.30    ...   4.90   V
12. V-ol Error Amplifier   0.00    ...   1.00   V
13. V-ref Output Voltage    5.05    ...   5.15   V
14. Line Regulation         0.0     ...   20.0   mV
15. Load Regulation        0.0     ...   15.0   mV
16. Isc - Voltage Ref.     not active
17. Current Sense Gain     2.50    ...   3.00   V/V
18. Current Sense V-Diff   not active
19. Vos Current Sense      not active
20. CMRR Current Sense     not active
21. PSRR Current Sense     not active
22. Current Sense +IBias   -3.00   ...   0.00   uA
23. Current Sense -IBias   -3.00   ...   0.00   uA
24. Current Sense Ios       0.00    ...   1.00   uA
25. V-oh Sync Output       2.40    ...   5.00   V
26. V-ol Sync Output       0.00    ...   0.40   V
27. V-ih/V-il Sync Input   not active
28. I-in Sync Input        not active
29. Initial Accuracy       not active
30. Voltage Stability      not active
31. Vos Current Limit      not active
32. Current Limit I-Bias   -30.00  ...   0.00   uA
33. Shutdown V-th         not active
34. Shutdown I-N-Latch     0.80    ...   3.00   mA
35. UVLO Shutdown V-th    not active
36. UVLO Start-Up V-th    not active
37. Vc Leakage Current     0.00    ...   200.00  uA
38. VOL @ 20mA            0.00    ...   0.50   V
39. VOL @ 200mA           0.00    ...   2.60   V
40. VOH @ 20mA            not active
41. VOH @ 200mA           not active
=====

```

	18	21	22	26	27
1.1 [mA]	17.67	15.93	16.88	16.76	16.75
3.1 [uA]	-0.12	-0.86	-0.84	-0.88	-0.81
4.1 [uA]	-0.12	-0.76	-0.74	-0.76	-0.68
5.1 [nA]	1.17	98.50	101.33	116.67	128.17
6.1 [dB]	87.611	87.715	87.747	90.063	87.474
8.1 [dB]	93.4	93.4	93.4	93.4	93.4
10.1 [mA]	-0.49	-0.36 F	-0.37 F	-0.37 F	-0.38 F
11.1 [V]	4.65	4.52	4.57	4.62	4.63
12.1 [V]	0.73	0.71	0.73	0.73	0.73
13.1 [V]	5.09	5.01 F	5.04 F	5.09	5.10
14.1 [mV]	3.2	9.5	10.8	1.3	0.3
15.1 [mV]	0.6	1.3	0.6	0.7	3.7
17.1 [V/V]	2.60	2.60	2.60	2.60	2.60
22.1 [uA]	-0.43	-2.63	-2.73	-2.73	-2.23
23.1 [uA]	-0.43	-2.65	-2.67	-2.71	-2.30
24.1 [uA]	0.00	0.02	0.06	0.02	0.07
25.1 [V]	3.90	3.80	3.84	3.85	3.86
26.1 [V]	0.33	0.32	0.32	0.34	0.34
32.1 [uA]	-7.06	-22.10	-22.94	-22.56	-22.83
34.1 [mA]	2.51	3.09 F	2.71	2.76	3.11 F
37.1 [uA]	0.07	0.06	0.06	0.12	0.07
38.1 [V]	0.31	0.30	0.31	6.67 F	0.38
38.2 [V]	0.28	0.29	0.29	1.09 F	0.30
39.1 [V]	0.81	1.74	1.14	1.39	1.50
39.2 [V]	0.77	1.65	1.07	1.24	1.45

SZ-TESTSYSTEME Statistics 03 Vers. 2.15 for UTS3
 RD241_UC1856J_POST_ANNEAL_EMS / V 1.0 IR 04/09/96 ROOM TEMP

```

=====
Results file   : RD241_UC1856J_POST_ANNEAL_EMS   from: 07.08.97 / 09:02:37
Operator      : PAUL RUSSELL
Part number   : UC1856J
Lot number    : RD241
Order number  : D/C 9344A
Vendor       : UNITRODE
              : CONTROL 18 ; RAD 21,22,26,27
              : POST ANNEAL EMS
              : UC1856 HUY-SP-IG-105 ISSUE 2 RM / V1.0 IR 04/09/96 ROOMTEMP
=====
  
```

Test steps

1. Supply Current	0.00	...	23.00	mA
2. Vos Error Amplifier	not active			
3. +I.Bias - Error Amp.	-1.00	...	0.00	uA
4. -I.Bias - Error Amp.	-1.00	...	0.00	uA
5. Ios - Error Amp.	0.00	...	500.00	nA
6. Avs Error Amplifier	80.000	...	120.000	dB
7. PSRR Error Amplifier	not active			
8. CMRR Error Amplifier	75.0	...	140.0	dB
9. I-Sink Error Amp.	not active			
10. I-Source Error Amp.	-10.00	...	-0.40	mA
11. V-oh Error Amplifier	4.30	...	4.90	V
12. V-ol Error Amplifier	0.00	...	1.00	V
13. V-ref Output Voltage	5.05	...	5.15	V
14. Line Regulation	0.0	...	20.0	mV
15. Load Regulation	0.0	...	15.0	mV
16. Isc - Voltage Ref.	not active			
17. Current Sense Gain	2.50	...	3.00	V/V
18. Current Sense V-Diff	not active			
19. Vos Current Sense	not active			
20. CMRR Current Sense	not active			
21. PSRR Current Sense	not active			
22. Current Sense +IBias	-3.00	...	0.00	uA
23. Current Sense -IBias	-3.00	...	0.00	uA
24. Current Sense Ios	0.00	...	1.00	uA
25. V-oh Sync Output	2.40	...	5.00	V
26. V-ol Sync Output	0.00	...	0.40	V
27. V-ih/V-il Sync Input	not active			
28. I-in Sync Input	not active			
29. Initial Accuracy	not active			
30. Voltage Stability	not active			
31. Vos Current Limit	not active			
32. Current Limit I-Bias	-30.00	...	0.00	uA
33. Shutdown V-th	not active			
34. Shutdown I-N-Latch	0.80	...	3.00	mA
35. UVLO Shutdown V-th	not active			
36. UVLO Start-Up V-th	not active			
37. Vc Leakage Current	0.00	...	200.00	uA
38. VOL @ 20mA	0.00	...	0.50	V
39. VOL @ 200mA	0.00	...	2.50	V
40. VOH @ 20mA	not active			
41. VOH @ 200mA	not active			

	18	21	22	26	27
1.1 [mA]	17.70	16.26	16.95	25.50 FI	16.75
3.1 [uA]	-0.13	-0.88	-0.84	-12.58 FI	-0.80
4.1 [uA]	-0.12	-0.79	-0.74	-12.59 FI	-0.68
5.1 [nA]	5.50	89.17	99.50	2.83	126.33
6.1 [dB]	88.156	87.852	87.920	84.145	89.842
8.1 [dB]	93.4	93.4	93.4	100.5	93.4
10.1 [mA]	-0.50	-0.38 FI	-0.39 FI	24.28 FI	-0.40 FI
11.1 [V]	4.66	4.55	4.58	0.25 FI	4.63
12.1 [V]	0.74	0.73	0.73	1.03 FI	0.73
13.1 [V]	5.10	5.01 FI	5.04 FI	5.94 FI	5.10
14.1 [mV]	3.0	14.1	14.6	237.3 FI	3.0
15.1 [mV]	5.0	2.7	0.1	32.1 FI	0.5
17.1 [V/V]	2.60	2.60	2.60	2.60	2.60
22.1 [uA]	-0.44	-2.64	-2.68	-12.58 FI	-2.24
23.1 [uA]	-0.42	-2.62	-2.63	-12.59 FI	-2.34
24.1 [uA]	0.02	0.02	0.05	0.00	0.10
25.1 [V]	3.90	4.14	3.82	0.00 FI	3.85
26.1 [V]	0.31	0.31	0.31	0.31	0.32
32.1 [uA]	-6.68	-23.28	-23.52	-0.00	-23.56
34.1 [mA]	2.55	2.72	2.67	0.00 FI	2.71
37.1 [uA]	0.07	0.06	0.06	0.00	0.07
38.1 [V]	0.32	0.37	0.29	4.68 FI	6.56 FI
38.2 [V]	0.31	0.30	0.29	7.20 FI	1.31 FI
39.1 [V]	0.98	1.68	1.07	13.06 FI	1.38
39.2 [V]	0.81	1.64	1.01	13.13 FI	13.44 FI

```

=====
Results file   : RD241_UC1856J_FINAL_EMS   from: 15.08.97 / 14:05:36
Operator      : PAUL RUSSELL
Part number   : UC1856J
Lot number    : RD241
Order number  : D/C 9344A
Vendor       : UNITRODE
              : CONTROL 18 ; RAD 21,22,27
              : FINAL EMS @ IGG
              : UC1856 HUY-SP-IG-105 ISSUE 2 RM / V1.0 IR 04/09/96 ROOMTEMP
=====
  
```

Test steps

1. Supply Current	0.00	...	23.00	mA
2. Vos Error Amplifier	not active			
3. +I.Bias - Error Amp.	-1.00	...	0.00	uA
4. -I.Bias - Error Amp.	-1.00	...	0.00	uA
5. Ios - Error Amp.	0.00	...	500.00	nA
6. Avs Error Amplifier	80.000	...	120.000	dB
7. PSRR Error Amplifier	not active			
8. CMRR Error Amplifier	75.0	...	140.0	dB
9. I-Sink Error Amp.	not active			
10. I-Source Error Amp.	-10.00	...	-0.40	mA
11. V-oh Error Amplifier	4.30	...	4.90	V
12. V-ol Error Amplifier	0.00	...	1.00	V
13. V-ref Output Voltage	5.05	...	5.15	V
14. Line Regulation	0.0	...	20.0	mV
15. Load Regulation	0.0	...	15.0	mV
16. Isc - Voltage Ref.	not active			
17. Current Sense Gain	2.50	...	3.00	V/V
18. Current Sense V-Diff	not active			
19. Vos Current Sense	not active			
20. CMRR Current Sense	not active			
21. PSRR Current Sense	not active			
22. Current Sense +IBias	-3.00	...	0.00	uA
23. Current Sense -IBias	-3.00	...	0.00	uA
24. Current Sense Ios	0.00	...	1.00	uA
25. V-oh Sync Output	2.40	...	5.00	V
26. V-ol Sync Output	0.00	...	0.40	V
27. V-ih/V-il Sync Input	not active			
28. I-in Sync Input	not active			
29. Initial Accuracy	not active			
30. Voltage Stability	not active			
31. Vos Current Limit	not active			
32. Current Limit I-Bias	-30.00	...	0.00	uA
33. Shutdown V-th	not active			
34. Shutdown I-N-Latch	0.80	...	3.00	mA
35. UVLO Shutdown V-th	not active			
36. UVLO Start-Up V-th	not active			
37. Vc Leakage Current	0.00	...	200.00	uA
38. VOL @ 20mA	0.00	...	0.50	V
39. VOL @ 200mA	0.00	...	2.60	V
40. VOH @ 20mA	not active			
41. VOH @ 200mA	not active			

	18	21	22	27
1.1 [mA]	17.67	16.38	17.00	16.22
3.1 [uA]	-0.12	-0.48	-0.49	-0.52
4.1 [uA]	-0.11	-0.47	-0.47	-0.49
5.1 [nA]	13.00	17.83	23.83	30.83
6.1 [dB]	87.828	90.068	89.918	89.954
8.1 [dB]	93.4	93.4	93.4	56.4 FI
10.1 [mA]	-0.50	-0.45	-0.46	-0.44
11.1 [V]	4.65	4.55	4.58	4.56
12.1 [V]	0.73	0.73	0.73	0.73
13.1 [V]	5.10	4.98 FI	5.01 FI	5.00 FI
14.1 [mV]	3.2	33.9 FI	35.0 FI	36.5 FI
15.1 [mV]	1.4	1.2	2.3	0.6
17.1 [V/V]	2.60	2.60	2.60	0.00 FI
22.1 [uA]	-0.42	-1.52	-1.53	-1.70
23.1 [uA]	-0.60	-1.77	-1.49	-1.71
24.1 [uA]	0.17	0.25	0.03	0.02
25.1 [V]	3.90	4.14	3.81	3.85
26.1 [V]	0.30	0.30	0.31	0.33
32.1 [uA]	-6.80	-19.85	-19.65	-19.50
34.1 [mA]	2.52	2.61	2.52	0.00 FI
37.1 [uA]	0.07	0.06	0.06	0.00
38.1 [V]	0.29	3.18 FI	6.65 FI	12.42 FI
38.2 [V]	0.29	1.07 FI	2.85 FI	11.95 FI
39.1 [V]	0.83	1.46	0.87	13.50 FI
39.2 [V]	0.79	1.07	0.86	13.43 FI