



**TOP - REL**

**Radiation Verification Test**

**Report**

**on**

**3C91C**

**from MITEL**

**Doc. N° TPR/RPT/082**

Issue/ Revision	Date	Prepared	Checked	Approved
1	Dec. 97	D. Gammone	V. Thomai	G. Cucinella
			<i>[Signature]</i>	<i>[Signature]</i>

CADM RELEASE  
13/12/97



Top Rel

Doc. N° TPR/RPT/082

PAGE 2

ISSUE 1

ISSUE	ISSUE DATE	PAGE AFFECTED	COMMENTS
1	Dec. 97	All	Initial Issue



## Abstract

This report contains the following parts:

- \* Radiation Verification Test Plan
- \* Certificate of Irradiation
- \* Certificate of Dosimetry
- \* Radiation Verification Test Results including :
  - ⇒ Tables measurements
  - ⇒ Graphs

## RVT Plan

RVT Plan includes all test conditions and the parameters to be measured. Parameter limits refer to Electrical Measurements Table of Detail specification SCC/5401-001.

## RVT Results

Irradiation steps have been 10-20-30-50-75-100 kRads.

Dose Rate has been around 9,5Rad/s.

Test temperature has been 25°C.

Three parts have been tested and another has been used as control sample.

After irradiation (100kRad accumulated) the devices have been annealed for 24 hours at 25°C.

Lot Date Code has been 9144A.

All parameters measured during this test stay within specification limits up to 75kRads. At 100kRads one parameter IC has slightly degraded under minimum limit. After 24h annealing the parameter continued to stay out of specification limit.



Top-Rel

RADIATION VERIFICATION TEST PLAN TPR/RPT/079

ISSUE N°: 1 REV. DATE: 17/11/97 PAGE: 1/2

Component Number: 540100102B Component Designation: 3C91C Irradiation Spec n°: SCC/22900 Issue: 2 Rev.

Specification: Generic: SCC/5000 I ss. 8A Detail: SCC/5401-001 I ss. 3D Acceptance: Diffusion [ ] Lot [X] Sample Size: 3 Control Devices: 1 Project / Programme: LABEN REQUEST

Family: OPTOELECTRONICS Group: OPTO ISOLATOR Package: Metal CAN

Manufacturer: MITEL Test House: TOP-REL Originator: TOP-REL Address: Jarfalla, SWEDEN Address: Via Dei Berio,91-00155 ROMA Name: V. THOMAI Telephone: +39(6)2282279

Facility: ENEA Source: CO60 Irradiation: Single [ ] Multiple [X] Irradiation Measurement Interval: Biased [ ] Unbiased [X] Circuit Ref.: N/A Supply Volt.: N/A Level of Interest: 50 kRad T (°C): Room Duration: 1H max

Table with irradiation steps and dose rates. Columns: Single Irradiation, Multiple Irradiation Steps, 1-8. Rows: Dose (kRad(Si)), Dose Rate (Rad(Si)/s), Exposure Time (H).

Irradiation Conditions: Biased (Remote Test) [X] Bias Circuit Ref: see figure Unbiased (Remote Test) [ ] Supply Voltages: see figure In Situ Test [ ] T (°C): Room Anneal Test: Biased [X] Bias Circuit Ref: Unbiased [ ] Supply Volt.: T (°C) [25] Duration: 24H

Table with 3 columns: Test Step, Description, Requirement. Rows 1-7 detailing test steps from serialisation to test report.

Table with 5 columns: Flow, Name, Signatures, Company, Date. Rows for PREPARED, APPROVED, APPROVED, APPROVED.



Top-Rel

RADIATION VERIFICATION  
TEST  
**PLAN**  
TPR/RPT/079

ISSUE N°. 1 REV.  
DATE: 17/11/97  
PAGE: 2/2

Component Number  
540100102B


Component Designation  
3C91C

Irradiation Spec n°. SCC/22900  
Issue 2 Rev.

TABLE 1: ELECTRICAL MEASUREMENTS AFTER EACH IRRADIATION STEP

N°		CHARACTERISTICS	SYMBOL	MIL-STD-750 TEST METHOD	TEST CONDITIONS	LIMITS		UNIT
						MIN	MAX	
1	LED	Forward Voltage	$V_F$	4011	$I_F = 2 \text{ mA}$	-	1.3	V
2		Forward Voltage	$V_F$	4011	$I_F = 50 \text{ mA}$	-	1.8	V
3		Breakdown Voltage	$V_{BR}$	4021	$I_R = 0.1 \text{ mA}$	7	-	V
4	Detector	Collector-Emitter - Breakdown Voltage	$V_{BRCEO}$	3011	$I_C = 10 \text{ mA}$	50	-	V
5		Dark Current	$I_{CEO}$	3036	$V_{CE} = 5V$ $I_F = 0 \text{ mA}$	-	50	nA
6	Coupled Device	Output Current	$I_C$	3036	$V_{CE} = 5V$ $I_F = 10 \text{ mA}$	4	-	mA
7		Collector-Emitter Saturation Voltage	$V_{CEsat}$	3030	$I_C = 2 \text{ mA}$ $I_F = 50 \text{ mA}$	-	0.4	V

FIGURE 1: RADIATION TEST BIAS CIRCUIT



<b>ENEA</b> INNOVAZIONE SERVIZI TECNOLOGICI IMPIANTO IRRAGGIAMENTO CALLIOPE	Sigla di identificazione :	Data:	Pag. / di pag.
	Commissa n°:	Num.:	Firma Operatore:
		1/12/97	1/2
		5/97	Pasquoli Ouylo

## CERTIFICATO DI IRRAGGIAMENTO

Descrizione campione: IRRAGGIAMENTO DI COMPONENTI ELETTRONICI

Numero ident: 3C91C e CMP05BJ

Richiedente: TOP-REL

Documenti di riferimento: FAX TPR/3021-97 DEL 13/11/97

### RIFERIMENTI DOSIMETRICI

Certificato di dosimetria: NUM. 3/97 DEL 19/11/97

Inizio irraggiamento: ORE 08.30 DEL 28/11/97

Fine irraggiamento: ORE 14.30 DEL 28/11/97

#### Condizioni ambientali :

temperatura : 20.9 (°C)      pressione: 1 (atm)

tipo di atmosfera : ARIA      um.rel. : 33.7 (%)

Note: E' STATO UTILIZZATO LA MEDIA DEI PUNTI DOSIMETRICI TROVATI.

IL RATEO UTILIZZATO E' COMPRENSIVO DEL DECADIMENTO NATURALE DELLA Sorgente

LE DOSI ASSORBITE S'INTENDONO CUMULATE SUI SINGOLI COMPONENTI.



**INNOVAZIONE  
SERVIZI TECNOLOGICI**

**IMPIANTO IRRAGGIAMENTO  
CALLIOPE**

Sigla di identificazione:

Data:

Pag. / di pag.

1/12/97

1/2

Commessa n°:

Num.:

Firma Operatore:

5/97

## CERTIFICATO DI IRRAGGIAMENTO

Punto Identific.	Intensità di dose Inizio Irragg. (Gy/.)	Intensità di dose Fine Irragg. (Gy/.)	Tempo di Irraggiamento (hh:mm:ss)	Dose richiesta (Gy)	Dose assorbita (Gy)	Differenza dalla dose richiesta (%)
1	343.3	343.3	00:17:29	100	100.03	0.03
2	343.3	343.3	00:17:29	100	100.03	0.03
3	343.3	343.3	00:17:29	100	100.03	0.03
4	343.3	343.3	00:34:58	200	200.06	0.03
5	343.3	343.3	00:43:42	250	250.04	0.016
6	343.3	343.3	00:43:42	250	250.04	0.016
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						

**ENEA** INNOVAZIONE  
SERVIZI TECNOLOGICI  
IMPIANTO IRRAGGIAMENTO  
CALLIOPE

Sigla di identificazione:

Data:

1/12/97

Pag. / di pag.

1/2

Commessa n°:

Num.:

3/97

Firma Operatore:

Pasquoli Angelo

## CERTIFICATO DI DOSIMETRIA

Dosimetria effettuata in data 19/11/97 alle ore: 09.15

Strumentazione utilizzata: Spettrofotometro UV/Vis Bekman DU-6

Tipo di dosimetro usato:

Soluzione Fricke

Red Perspex

La dosimetria è stata effettuata in conformità alle specifiche riportate nel documento Enea TDI 87011A

## RISULTATI DOSIMETRICI

Numero dosimetro	Tempo di irraggiamento (hh:mm:ss)	Dosa assorbita (Gy)	Intensità di dose (Gy/h)
1	00 : 30 : 00	170.844	341.688
2	00 : 30 : 00	167.808	335.616
3	00 : 30 : 00	173.604	347.208
4	00 : 30 : 00	175.812	351.624
5	00 : 30 : 00	173.052	346.104
6	: :		
7	: :		
8	: :		
9	: :		
10	: :		



**ENEA** INNOVAZIONE  
 SERVIZI TECNOLOGICI  
 IMPIANTO IRRAGGIAMENTO  
 CALLOPE

Segna di identificazione :

Data:

1/12/97

Pag. / di pag.

2 / 2


Commessa n°:

Num.:


3/97

Firma Operatore:

### CERTIFICATO DI DOSIMETRIA



DOSIMETRO




PANNELLO DI  
 POLISTIROLO

PANNELLO DI  
 POLISTIROLO

1

DOSIMETRO

SORGENTE



127cm

Part Type : 3C91C  
 Manufacturer : ABB HAFO  
 Detail Spec.: SCC/5401-001

Sample size : 4 (3+1)  
 Irradiated Samples: s/n 213,217,569  
 Control Sample: s/n 571  
 Date Code : 9144A

Equipment(s) : HP4142B  
 Calibration is : VALID  
 Test Prg. No.: 01


Irradiation steps : 10-20-30-50-75-100 kRad  
 Annealing : 24 h  
 Dose Rate : 9,5 Rad/s  
 Temperature for test : +25°C

Operator : D. GAMMONE  
 Date : 28/11/97

Test House : TOP-REL  
 Test Source : CO60 Calliope / ENEA, Casaccia

1-  $V_F$  (2mA)

	0KRad	10KRad	20KRad	30KRad	50KRad	75KRad	100KRad	Annealing
Min.	-	-	-	-	-	-	-	-
Max.	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3
213	1.07272	1.07148	1.07148	1.07076	1.0664	1.06168	1.05736	1.06068
217	1.06952	1.07224	1.0682	1.07096	1.06684	1.06132	1.06216	1.06256
569	1.06368	1.06712	1.05956	1.06616	1.06232	1.05744	1.05148	1.05648
571	1.0736	1.07756	1.07908	1.0776	1.07548	1.07272	1.07348	1.07376



Part Type : 3C91C  
 Manufacturer : ABB HAFO  
 Detail Spec.: SCC/5401-001

Sample size : 4 (3+1)  
 Irradiated Samples: s/n 213,217,569  
 Control Sample: s/n 571  
 Date Code : 9144A

Equipment(s) : HP4142B  
 Calibration is : VALID  
 Test Prg. No.: 01


Irradiation steps : 10-20-30-50-75-100 kRad  
 Annealing : 24 h  
 Dose Rate : 9,5 Rad/s  
 Temperature for test : +25°C

Operator : D. GAMMONE  
 Date : 28/11/97

Test House : TOP-REL  
 Test Source : CO60 Calliope / ENEA, Casaccia

2-  $V_F$  (50mA)

	0KRad	10KRad	20KRad	30KRad	50KRad	75KRad	100KRad	Annealing
Min.	-	-	-	-	-	-	-	-
Max.	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8
213	1.25956	1.25908	1.25976	1.25984	1.25728	1.2542	1.252	1.25472
217	1.25892	1.26252	1.25936	1.2626	1.2604	1.25668	1.25892	1.2592
569	1.27364	1.278	1.271	1.27848	1.2764	1.27292	1.26872	1.27552
571	1.27352	1.27764	1.27872	1.27716	1.27564	1.27244	1.27304	1.27348



Part Type : 3C91C  
 Manufacturer : ABB HAFO  
 Detail Spec.: SCC/5401-001

Sample size : 4 (3+1)  
 Irradiated Samples: s/n 213,217,569  
 Control Sample: s/n 571  
 Date Code : 9144A

Equipment(s) : HP4142B  
 Calibration is : VALID  
 Test Prg. No.: 01


Irradiation steps : 10-20-30-50-75-100 kRad  
 Annealing : 24 h  
 Dose Rate : 9,5 Rad/s  
 Temperature for test : +25°C

Operator : D. GAMMONE  
 Date : 28/11/97

Test House : TOP-REL  
 Test Source : CO60 Calliope / ENEA, Casaccia

3-  $V_{BR}$

	0KRad	10KRad	20KRad	30KRad	50KRad	75KRad	100KRad	Annealing
Min.	-	-	-	-	-	-	-	-
Max.	-7	-7	-7	-7	-7	-7	-7	-7
213	-8.0104	-8.0024	-8.0032	-8.0008	-8.0012	-8	-8.0008	-8.0132
217	-8.0104	-8.0024	-8.0032	-8.0008	-8.0012	-8.0004	-8.0008	-8.0132
569	-8.0104	-8.0024	-8.0032	-8.0008	-8.0012	-8	-8.0004	-8.0132
571	-8.0104	-8.0024	-8.0032	-8.0008	-8.0012	-8.0004	-8.0004	-8.0128



Part Type : 3C91C  
 Manufacturer : ABB HAFO  
 Detail Spec.: SCC/5401-001

Sample size : 4 (3+1)  
 Irradiated Samples: s/n 213,217,569  
 Control Sample: s/n 571  
 Date Code : 9144A

Equipment(s) : HP4142B  
 Calibration is : VALID  
 Test Prg. No.: 01


Irradiation steps : 10-20-30-50-75-100 kRad  
 Annealing : 24 h  
 Dose Rate : 9,5 Rad/s  
 Temperature for test : +25°C

Operator : D. GAMMONE  
 Date : 28/11/97

Test House : TOP-REL  
 Test Source : CO60 Calliope / ENEA, Casaccia

4-  $V_{BRCEO}$

	0KRad	10KRad	20KRad	30KRad	50KRad	75KRad	100KRad	Annealing
Min.	5.00E+01	5.00E+01	5.00E+01	5.00E+01	5.00E+01	5.00E+01	5.00E+01	5.00E+01
Max.	-	-	-	-	-	-	-	-
213	52.006	51.994	51.996	51.996	51.996	51.996	51.996	52.014
217	52.008	51.994	51.996	51.996	51.996	51.996	51.996	52.014
569	52.008	51.994	51.996	51.996	51.996	51.996	51.996	52.014
571	52.006	51.994	51.996	51.996	51.996	51.996	51.996	52.014



Part Type : 3C91C  
 Manufacturer : ABB HAFO  
 Detail Spec.: SCC/5401-001

Sample size : 4 (3+1)  
 Irradiated Samples: s/n 213,217,569  
 Control Sample: s/n 571  
 Date Code : 9144A

Equipment(s) : HP4142B  
 Calibration is : VALID  
 Test Prg. No.: 01


Irradiation steps : 10-20-30-50-75-100 kRad  
 Annealing : 24 h  
 Dose Rate : 9,5 Rad/s  
 Temperature for test : +25°C

Operator : D. GAMMONE  
 Date : 28/11/97

Test House : TOP-REL  
 Test Source : CO60 Calliope / ENEA, Casaccia

5- I<sub>CE</sub>

	0KRad	10KRad	20KRad	30KRad	50KRad	75KRad	100KRad	Annealing
Min.	-	-	-	-	-	-	-	-
Max.	5.00E-08	5.00E-08	5.00E-08	5.00E-08	5.00E-08	5.00E-08	5.00E-08	5.00E-08
213	7.27E-11	5.396E-11	6.38E-11	5.632E-11	5.456E-11	5.552E-11	4.5E-11	7.874E-11
217	3.6548E-10	2.24E-10	2.5846E-10	1.715E-10	1.2822E-10	1.326E-10	9.466E-11	1.298E-10
569	1.3112E-10	8.832E-11	1.626E-10	9.038E-11	5.952E-11	6.266E-11	6.756E-11	1.182E-10
571	1.5484E-10	9.848E-11	1.4264E-10	1.5948E-10	1.9402E-10	4.7624E-10	1.574E-10	1.48E-10



Part Type : 3C91C  
 Manufacturer : ABB HAFO  
 Detail Spec: SCC/5401-001

Sample size : 4 (3+1)  
 Irradiated Samples: s/n 213,217,569  
 Control Sample: s/n 571  
 Date Code : 9144A

Equipment(s) : HP4142B  
 Calibration is : VALID  
 Test Prg. No.: 01

Irradiation steps : 10-20-30-50-75-100 kRad  
 Annealing : 24 h  
 Dose Rate : 9,5 Rad/s  
 Temperature for test : +25°C

Operator : D. GAMMONE  
 Date : 28/11/97

Test House : TOP-REL  
 Test Source : CO60 Calliope / ENEA, Casaccia

7-  $V_{CESAT}$

	0KRad	10KRad	20KRad	30KRad	50KRad	75KRad	100KRad	Annealing
Min.	-	-	-	-	-	-	-	-
Max.	4.00E-01	4.00E-01	4.00E-01	4.00E-01	4.00E-01	4.00E-01	4.00E-01	4.00E-01
213	0.07472	0.08124	0.0834	0.0852	0.089	0.09304	0.09664	0.10036
217	0.0826	0.08652	0.08948	0.09032	0.09404	0.09836	0.1006	0.10444
569	0.08112	0.08544	0.08956	0.0896	0.09352	0.09784	0.10216	0.105
571	0.07628	0.07528	0.075	0.07528	0.07576	0.07636	0.07616	0.07628

