

D/TOS-QCA Final Presentation Day, ESA/ESTEC, Noordwijk, The Netherlands –
April 09, 2002.

60 MeV Proton Testing of 3C91C Optocouplers for ENVISAT-1, Summary Results.

by

¹R. Harboe-Sørensen, ²J.-F. Pascal & ²F.-X. Guerre

¹European Space Agency/ESTEC - The Netherlands
²HIREX Engineering, Toulouse - France

Abstract

Mitel 3C91C Optocoupler devices from ENVISAT-1 lots were 60 MeV proton irradiated at the Centre de Protontherapie d'Orsay, Orsay, France, February 16th, 2001. Radiation summary results covering the Current Transfer Ratio (CTR) degradation will be presented for different date codes and biasing irradiation conditions.



ESTEC - Radiation Effects and Analysis Techniques Section



Ref. : D/TOS-QCA/OPTO-09/02/2002

Objective:

To Radiation Evaluate 3C91C Optocouplers from ENVISAT-1 lots:

- Using 60 MeV Protons
- Using representative ENVISAT-1 Operating conditions (3C91C)

To Have Radiation Data before March 2001.

- HIREX Engineering, Toulouse – contacted week 3, 2001
- SOW Issued 18th January 2001 Radiation Evaluation
- All parts forwarded to HIReX week 5, 2001
- Test facility booked for 16th February 2001, (Centre de Protontherapie d'Orsay, France)
- Acceptance of test set-up, biasing boards and electrical measurements (Ref.; ESA/SCC Spec. 5401/001) – 8th February 2001
- CPO testing 16th February 2001
- Final report to be delivered in week 09, 2001

Why Proton Testing ?




Figure 1. An optocoupler's response to Co-60 compared to proton irradiations.

Ref.: K. A. LaBe et al, IEEE Trans. On Nucl. Sci. vol 46, No. 6, Dec. 1998.



ESTEC - Radiation Effects and Analysis Techniques Section



Ref. : D/TOS-QCA/OPTO-09/02/2002

Optocoupler Types Tested:

CPO – 60 MeV Proton Test	Reference Devices	Bias Conditions During Test		
		10 mA/5 V	2 mA/ 5 V	Unbiased
3C91C d/c 9508	1	2	1	1
3C91C d/c 9601	1	2	1	1
3C91C d/c 9519	1	2	1	1
3C91C d/c 9344	1	2	1	1
3C91C d/c 9426		3	3	3
3C91C d/c 9309		1		
ENVISAT-1 30 pc	4	12	7	7
3C91C L234	1	2	2	2
3C91C d/c 9806	1	1	1	1
CNES 11 pc	2	3	3	3
4N49 Isolink	1	2	2	2
4N49 Micropac	1	2	2	2
4N49 Optek	1	2	2	2
21 Devices	3	6	6	6

Test Conditions/Set-Up:

Electrical Testing – Ref.: ESA/SCC Spec. 5401/001

- Table 2 for DC Measurements – first 7 parameters
- With additional Output Current Test at $I_f = 1, 2 \& 5 \text{ mA}$
- Rise/Fall Time Test – Ref. Figure 4a

Parametric Testing

- DC - HP4142B connected to shielded DUT box
- AC - Pulse Generator/Oscilloscope

2 Biasing Boards prepared for parts to be irradiated:

- Unbiased
- $I_f = 2 \text{ mA}$ - Ref. Figure 5b
- $I_f = 10 \text{ mA}$ - Ref. Figure 5b

Electrical Measurements: DC/AC Parameters

Symbol	Description	Conditions	Min	Max	Unit
VF1	Forward Voltage 1	IF=2.0mA		1.3	V
VF2	Forward Voltage 2	IF=50mA		1.8	V
VBR	Breakdown Voltage	IR=0.1mA	7		V
VBRCE0	Collector-Emitter Breakdown Voltage	IC=10mA	50		V
ICE0	Dark Current	VCE=5.0V. IF=0mA		5.0E-08	A
IC1	Output Current1	VCE=5.0V. IF=1mA			A
IC2	Output Current2	VCE=5.0V. IF=2mA			A
IC5	Output Current5	VCE=5.0V. IF=5mA			A
IC10	Output Current10	VCE=5.0V. IF=10mA	0.004		A
VCESAT	Collector Emitter Saturation Voltage	IC=2mA. IF=50mA		0.4	V
trise	Rise Time	RL=100 Ohms. IC=2.0mA. VCE=5.0V		5.0E-06	s
tfall	Fall Time	RL=100 Ohms. IC=2.0mA. VCE=5.0V		5.0E-06	s
CTR1					%
CTR2					%
CTR5					%
CTR10					%

DC: Electrical Parameters (example after 3.63E10 p/cm²)

Bias	VF1	VF2	VBR	VBRCE0	ICE0	IC_1mA	IC_2mA	IC_5mA	IC_10mA	VCESAT	date code	#
Ref	1.077	1.314	26.884	57.376	350.34E-12	593.14E-6	1.7432E-3	6.061E-3	13.918E-3	32.40E-3	DC9344	029
Ref	1.073	1.246	25.146	59.718	173.16E-12	467.96E-6	1.413E-3	5.0416E-3	11.782E-3	32.68E-3	DC9508	179
Ref	1.069	1.229	26.076	76.136	551.86E-12	321.28E-6	951.04E-6	3.4134E-3	8.1248E-3	81.00E-3	L234	1
Unbiased	1.061	1.251	31.338	58.764	251.02E-12	211.06E-6	668.92E-6	2.6726E-3	6.9226E-3	51.48E-3	DC9344	046
Unbiased	1.063	1.308	30.178	59.800	178.96E-12	155.62E-6	509.92E-6	2.1106E-3	5.5892E-3	55.52E-3	DC9426	29
Unbiased	1.061	1.262	23.302	60.312	226.72E-12	163.58E-6	545.50E-6	2.2992E-3	6.1612E-3	54.28E-3	DC9426	38
Unbiased	1.057	1.266	29.922	56.572	72.56E-12	115.68E-6	369.20E-6	1.4908E-3	3.9046E-3	51.52E-3	DC9806	627
Unbiased	1.054	1.243	31.998	76.302	510.18E-12	125.90E-6	403.18E-6	1.6532E-3	4.4106E-3	96.48E-3	L234	2
Unbiased	1.053	1.247	41.428	68.102	550.38E-12	157.74E-6	511.24E-6	2.103E-3	5.5616E-3	87.40E-3	L234	3
2 mA	1.060	1.272	22.170	60.100	149.76E-12	178.92E-6	580.18E-6	2.3744E-3	6.2398E-3	52.64E-3	DC9508	280
2 mA	1.059	1.246	30.160	60.136	531.62E-12	146.60E-6	462.30E-6	1.833E-3	4.7242E-3	61.20E-3	DC9519	167
2 mA	1.058	1.262	26.668	56.584	269.98E-12	229.30E-6	730.60E-6	2.925E-3	7.559E-3	41.92E-3	DC9601	282
2 mA	1.060	1.247	29.306	53.690	121.98E-12	183.98E-6	562.56E-6	2.1572E-3	5.458E-3	40.32E-3	DC9806	739
2 mA	1.056	1.221	30.894	75.876	462.52E-12	185.00E-6	584.92E-6	2.3458E-3	6.1002E-3	86.04E-3	L234	4
2 mA	1.060	1.242	42.666	69.070	616.52E-12	155.34E-6	495.78E-6	2.0122E-3	5.2646E-3	98.24E-3	L234	5
10 mA	1.059	1.277	31.376	58.586	222.60E-12	228.02E-6	745.94E-6	3.046E-3	7.9332E-3	47.12E-3	DC9309	097
10 mA	1.057	1.253	24.834	61.206	310.96E-12	103.64E-6	341.92E-6	1.4236E-3	3.7734E-3	65.48E-3	DC9519	107
10 mA	1.060	1.269	34.120	60.564	166.16E-12	162.16E-6	533.82E-6	2.1522E-3	5.534E-3	54.80E-3	DC9519	241
10 mA	1.053	1.240	27.590	55.142	446.24E-12	294.34E-6	939.88E-6	3.7066E-3	9.4174E-3	38.92E-3	DC9601	73
10 mA	1.059	1.246	27.148	57.616	186.74E-12	245.48E-6	774.88E-6	3.0268E-3	7.6408E-3	37.80E-3	DC9601	232
10 mA	1.057	1.238	19.552	53.984	150.84E-12	120.98E-6	396.98E-6	1.629E-3	4.281E-3	51.12E-3	DC9806	694
10 mA	1.050	1.222	34.064	70.260	480.18E-12	197.40E-6	634.60E-6	2.6104E-3	6.9122E-3	78.04E-3	L234	6
10 mA	1.059	1.226	30.648	74.780	363.34E-12	132.24E-6	414.98E-6	1.6352E-3	4.1826E-3	95.12E-3	L234	7




ESTEC - Radiation Effects and Analysis Techniques Section



Ref. : D/TOS-QCA/OPTO-09/02/2002

Current Transfer Ratio (CTR)



CTR is defined as the Collector Current (I_C) in the Detector
Divided by the LED Forward Current (I_F).

Centre de Protontherapie d'Orsay: 200 MeV proton beam

Synchro- cyclotron SC200 installed in Orsay in 1957

- Used for physics research until 1990
- Devoted to Medical Treatment since 1991
- However, open for other applications during night and weekend hours.

Used Test Conditions

- Energy: 60 MeV
- Beam size Ø: 10 cm
- Flux: 2.7E07 p/cm²/sec.
- Calibration: On-line ionization chambers
- Beam Profile: horizontal/vertical




ESTEC - Radiation Effects and Analysis Techniques Section



Ref. : D/TOS-QCA/OPTO-09/02/2002

CPO: Beam Profile



ESTEC - Radiation Effects and Analysis Techniques Section




Ref. : D/TOS-QCA/OPTO-09/02/2002


CPO: 60 MeV Proton - Irradiation Steps

Irr. Steps p/cm ²	Fluence p/cm ²	Irr. Time Seconds	Temp. °C
0			22
7.26E09	7.26E09	269	22
1.10E10	1.82E10	407	22
1.82E10	3.63E10	674	22
3.63E10	7.26E10	1344	22
7.26E10	1.50E11	2688	22
per board – 2 boards Irradiated			
Flux : 2.70E07 p/cm ² /sec.			


CTR Results: Unbiased/CTR = 1 mA




CTR Results: Bias = 2 mA/CTR = 1 mA




CTR Results: Bias = 10 mA/CTR = 1 mA




CTR Results: Unbiased/CTR = 1, 2, 5 & 10 mA




CTR Results: Bias = 2 mA/CTR = 1, 2, 5 & 10 mA




CTR Results: Bias = 10 mA/CTR = 1, 2, 5 & 10 mA



CTR Results: Unbiased/Bias = 10 mA - CTR = 1 & 10 mA



Rise & Fall Time Results: d/c 9426



ENVISAT-1 3C91C Optocoupler Testing: Conclusion

Within a 12 hours test slot at CPO, various Optocoupler parts were fully radiation characterized using a 60 MeV proton beam – addressing both bias and CTR conditions.

Characterized parts covered:

- 30 Mitel 3C91C parts from ENVISAT-1 (6 different date codes)
- 7 Mitel 3C91C parts from SPOT-1
- 4 Mitel 3C91C parts from SPOT-5
- 7 Isolink 4N49 parts for radiation evaluation
- 7 Micropac 4N49 parts for radiation evaluation
- 7 Optek 4N49 parts for radiation evaluation

Radiation data presented here were used for the final 3C91C Optocoupler Radiation Degradation Analysis for ENVISAT-1

Final test report available – <https://escies.org/public/radiation/>



ESTEC - Radiation Effects and Analysis Techniques Section



Ref. : D/TOS-QCA/OPTO-09/02/2002

D/TOS-QCA Final Presentation Day, ESA/ESTEC, Noordwijk, The Netherlands –
April 09, 2002.

60 MeV Proton Testing of 4N49 Optocouplers from Isolink, Micropac and Optek, Summary Results.

by

¹R. Harboe-Sørensen, ²J.-F. Pascal & ²F.-X. Guerre

¹European Space Agency/ESTEC - The Netherlands

²HIREX Engineering, Toulouse - France

Abstract

At the same time as the 3C91C proton testing was carried out for ENVISAT-1, a few 4N49 Optocoupler parts from Isolink, Micropac and Optek were also irradiated. Summary results covering the same biasing conditions and addressing the Current Transfer Ratio (CTR) degradation will be presented and compared with results obtained on the 3C91C.




ESTEC - Radiation Effects and Analysis Techniques Section




Ref. : D/TOS-QCA/OPTO-09/02/2002


Isolink 4N49 CTR Results: Unbiased, Biased 1 mA and 10 mA - CTR = 1 mA and 5 mA




Micropac 4N49 CTR Results: Unbiased, Biased 1 mA and 10 mA - CTR = 1 mA and 5 mA




Optek 4N49 CTR Results: Unbiased, Biased 1 mA and 10 mA - CTR = 1 mA and 5 mA



Isolink, Micropac and Optek 4N49 CTR Results: Unbiased and Bias = 10 mA - CTR = 1 mA



Isolink, Micropac, Optek 4N49 and Mitel 3C91 CTR Results: Unbiased - CTR = 1 mA



Isolink, Micropac, Optek 4N49 Optocoupler Testing: Conclusion

- # 4N49 Preliminary radiation CTR data presented here
- # Tested types show increased degradation of CTR when compared to the ENVISAT-1 3C91C lots.
- # At a 60 MeV proton fluence of 3.63E10 p/cm² – 4N49 Unbiased and I_F = 1 mA – the CTR was reduced to;
 - Isolink : 26 %
 - Micropac : 20 %
 - Optek : 21 %
- # Test report not available, however, presentation material to be found under –

5th QCA Presentation Day

<https://escies.org/public/radiation/>



ESTEC - Radiation Effects and Analysis Techniques Section



Ref. : D/TOS-QCA/OPTO-09/02/2002